

E RECORD

It is recommended that your heating system is serviced regularly and that the appropriate Service Interval Record is completed.

Provider

When completing the appropriate Service Record below, please ensure you have carried out the service as described in the manufacturer's instructions. Use the manufacturer's specified spare part when replacing controls.

SERVICE 01		Date: 05.09.17	
Engineer name: Adam			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO ppm	AND CO ₂ %
	At min. rate: (Where Possible)	CO ppm	AND CO ₂ %
Comments:			
Signature: <i>APW</i>			

SERVICE 02		Date: 15.10.18	
Engineer name: Adam			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO 2.9 ppm	AND CO ₂ % 8.9
	At min. rate: (Where Possible)	CO 2 ppm	AND CO ₂ % 8.3
Comments: Sure graft 10 added			
Signature: <i>APW</i>			

SERVICE 03		Date: 14.10.19	
Engineer name: Adam			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO 57 ppm	AND CO ₂ % 9.4
	At min. rate: (Where Possible)	CO 8 ppm	AND CO ₂ % 8.8
Comments: MAGNETIC FLUX SWIRL INHIBITOR MODERN P/C 1.5.			
Signature: <i>APW</i>			

SERVICE 04		Date: 20.09.21	
Engineer name: Alex			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO 35 ppm	AND CO ₂ % 9.0
	At min. rate: (Where Possible)	CO 0 ppm	AND CO ₂ % 8.7
Comments: Heat exchanger flushed & condensate trap cleaned. Magnetic filter cleaned P/C 1.5 bar			
Signature: <i>APW</i>			

SERVICE 05		Date: 28.09.22	
Engineer name: Alex			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO 34 ppm	AND CO ₂ % 9.0
	At min. rate: (Where Possible)	CO 1 ppm	AND CO ₂ % 8.8
Comments: Heat exchanger flushed, condensate trap & magnetic filter cleaned. P/C 1.5 bar.			
Signature: <i>APW</i>			

SERVICE 06		Date: 24.10.23	
Engineer name: Alex			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO 32 ppm	AND CO ₂ % 8.9
	At min. rate: (Where Possible)	CO 0 ppm	AND CO ₂ % 8.7
Comments: Condensate trap cleaned			
Signature: <i>APW</i>			

SERVICE 07		Date: 14.10.24	
Engineer name: Alex			
Company name: APW Services Ltd			
Telephone No: 01509 820 227			
Gas safe register No: 520 617			
Record:	At max. rate:	CO 30 ppm	AND CO ₂ % 8.8
	At min. rate: (Where Possible)	CO 2 ppm	AND CO ₂ % 8.5
Comments: Condensate trap & cleaned. Magnetic filter serviced.			
Signature: <i>APW</i>			

SERVICE 08		Date:	
Engineer name:			
Company name:			
Telephone No:			
Gas safe register No:			
Record:	At max. rate:	CO ppm	AND CO ₂ %
	At min. rate: (Where Possible)	CO ppm	AND CO ₂ %
Comments:			
Signature:			

SERVICE 09		Date:	
Engineer name:			
Company name:			
Telephone No:			
Gas safe register No:			
Record:	At max. rate:	CO ppm	AND CO ₂ %
	At min. rate: (Where Possible)	CO ppm	AND CO ₂ %
Comments:			
Signature:			

SERVICE 10		Date:	
Engineer name:			
Company name:			
Telephone No:			
Gas safe register No:			
Record:	At max. rate:	CO ppm	AND CO ₂ %
	At min. rate: (Where Possible)	CO ppm	AND CO ₂ %
Comments:			
Signature:			

*All installations in England and Wales must be notified to Local Authority Building Control (LABC) either directly or through a Competent Persons Scheme. A Building Regulations Compliance Certificate will then be issued to the customer.

